

MG COOLING SERVICES LTD

19 NORMAN ROAD, NORTHFIELD, BIRMINGHAM, B31 2ES

TEL: 0121 475 3454, MOBILE 07771 966839

Email: matt@mgcoolingservices.co.uk

Pressure Testing Certificate

Job Name: Girl Guides

Site: Winvic, Holloway Head, Birmingham

Job No: 2016

Area: Mez Floor

System: AN080AXVGR (DVM 52)

TEST PRESSURE COMMENCED:

BAR: 40 bar

Time: 09:00 AM

Date: 3/2/23

TEST PRESSURE COMPLETED:

BAR 39.5 bar

Time: 09:00 AM

Date: 4/2/23

LEAKS:

YES/NO

WITNESSED BY:

Michael McGrath M. McGrath

CLIENT: TNA

M.G. COOLING SERVICES Ltd.

J. GROCOTT



MG COOLING SERVICES LTD

19 NORMAN ROAD, NORTHFIELD, BIRMINGHAM, B31 2ES

TEL: 0121 475 3454, MOBILE 07771 966839

Email: matt@mgcoolingservices.co.uk

Pressure Testing Certificate

Job Name: Girl Guides

Site: Winvic, Holloway Head, Birmingham

Job No: 2016

Area: Lower Ground / Main Hall

System: AN200AXVGA R (DVM 52)

TEST PRESSURE COMMENCED:

BAR: 40 bar

Time: 09:00 AM

Date: 31/2/23

TEST PRESSURE COMPLETED:

BAR 39.5

Time: 09:00 AM

Date: 31/2/23

LEAKS:

YES/NO

WITNESSED BY:

Michael McGrath

M. McGrath

CLIENT: TNA

M.G. COOLING SERVICES Ltd.

J. GEOCOTT



MG COOLING SERVICES LTD

19 NORMAN ROAD, NORTHFIELD, BIRMINGHAM, B31 2ES

TEL: 0121 475 3454, MOBILE 07771 966839

Email: matt@mgcoolingservices.co.uk

Pressure Testing Certificate

Job Name: Girl Guides

Site: Winvic, Holloway Head, Birmingham

Job No: 2016

Area: Shop

System: AC140RxADKA (FCU 15)

TEST PRESSURE COMMENCED:

BAR: 40 bar

Time: 09:00 AM

Date: 31/2/23

TEST PRESSURE COMPLETED:

BAR 40 bar

Time: 09:00 AM

Date: 4/2/23

LEAKS:

YES/NO

WITNESSED BY: Michael McGrath M. McGrath

CLIENT: TNA

M.G. COOLING SERVICES Ltd.

J. GROCOTT

